

Controller Hardware-in-the-loop (C-HIL) Testing of Decentralized EV-Grid Integration

Calvin Flack, Emin Ucer, Charles Parker Smith, Mithat Kisacikoglu

Dept. of Electrical and Computer Engineering, The University of Alabama, Tuscaloosa, AL

E-mails: {eucer, caflack, cpsmith4}@crimson.ua.edu, mkisacik@ua.edu

Abstract— Present grid infrastructure is unprepared for the wide-scale integration of electric vehicles (EVs). Real-time grid simulation and hardware testing are necessary for the fast and accurate development of EV charging control strategies that are applicable in the field to mitigate their adverse effects. To help facilitate this goal, in this study, we develop a controller verification testbed using a baseline bidirectional AC/DC converter, commonly used in on-board EV chargers, within a hardware-in-the-loop (HIL) test system. The converter runs real-time on a very-fast time scale and integrates into an external grid simulator. We utilize the strength of the HIL device in simulating power electronics while simultaneously realizing a complex distribution grid operation in real-time. The whole system holistically provides an opportunity to see the implementation benefits of a decentralized charging algorithm on the voltage stability of the distribution grid. The study presents a step-by-step approach to developing and testing controllers, providing an essential contribution in the field demonstration of decentralized EV charger control strategies.

I. INTRODUCTION

Electric vehicles (EVs) will become more common in the coming years in the constant search for cleaner transportation. While EVs provide an alternative to traditional internal combustion engine (ICE) vehicles, they can significantly strain the distribution grid operation if mass integrated. An on-board EV charger can operate at a rate as high as the peak power consumption of a typical house [1]–[3]. Today, more than 80% of EV owners prefer to charge their EVs at home in the US [4]. In a world where most homes have an EV, it would easily overload the present grid equipment if the power demand were to nearly double as people return to their homes and start charging their vehicles. Smart and coordinated charging methods will be critical for the smooth integration of EVs on a mass scale.

While EVs can disturb the grid, they can also benefit it if adequately integrated. With minimal hardware modifications [5], [6], EV chargers can provide grid reactive power services to compensate for nearby inductive loads. Furthermore, studies show how EVs can filter the distortion created from other nearby loads [7]. Other studies explore altering the charging power to compensate for voltage drop during times of peak power usage to provide decentralized demand response to the grid [8].

Unidirectional EV chargers can only compensate for grid voltage drops by lowering their charging power. No more compensation can be provided if the drop is severe enough that

the charging power reaches a minimum. Bidirectional chargers allow full compensation as they are capable of supplying real power as well. Additionally, four-quadrant bidirectional chargers add the ability to inject or absorb reactive power in addition to real power. With the high power capability of EV chargers, bidirectional chargers could easily supply enough power to support short-term increased power demand. Whether it is a unidirectional or bidirectional, for all the ancillary services provided to the grid, the developed control algorithms should be practical and easily implemented in the field.

Hardware-in-the-loop (HIL) devices are used to simulate the function of a system in real-time. This way, power/control hardware external to the system can be tested. This is done by providing feedback from the simulated system to the external hardware while receiving signals from the hardware to influence the simulated system. HIL devices increase controller development speed and remove the need to build the full system or risk damage to components due to controller issues. These advantages have made HIL devices quite popular for their simplicity and ease of use. Past work using HIL devices showcased grid-tied AC/DC converter controllers and their impact on basic grid models [9], [10].

A decentralized Additive Increase Multiplicative Decrease (AIMD) charging algorithm was selected to increase grid stability because of its simplicity and ability to scale [11]. The literature on decentralized charging algorithms mainly focuses on simulated results [12]. These studies provide good insight into new strategies, but simulation alone can potentially omit real-world problems associated with controller implementation. There has also been limited work in real-time control algorithm validation, but with control algorithms different than AIMD [13]. Additionally, most proposed work utilizes simple grid models [14], [15] whereas we present a complex distribution system, modeling both primary and secondary sides down to a total of 320 end-nodes that have real power consumption profiles. This presents the opportunity to build a system for the purpose of validating a purely decentralized AIMD charging algorithm in real-time.

This paper will investigate the integration of a bidirectional AC/DC converter model realized on a fast time-scale Typhoon HIL 402 [16] simulator. A more complex grid simulation runs a versatile multi-core real-time digital simulator, OPAL-RT OP5600 [17]. The controller will utilize a decentralized AIMD algorithm to mitigate adverse grid impacts. The overall implementation accuracy of the algorithm will be assessed using a TI C2000 micro-controller.

This material is supported by the National Science Foundation under Award No 1755996.




Figure 1: AC/DC converter topology schematic.

Table I: System Specifications

Parameter	Symbol	Value
Charger apparent power	S	10 kVA
Grid voltage	V_s	240 V
Grid frequency	ω_0	$2\pi 60$ rad/s
Switching frequency	f_{sw}	72 kHz
Filter Inductance	L_s	500 μ H
Output voltage	V_{dc}	340-800 V
Output capacitance	C_{dc}	500 μ F
Output equivalent resistance	R_{dc}	60 Ω

II. SYSTEM DESCRIPTION AND MODELING

A. On-board Charger Power Electronics Topology

In typical two-stage on-board chargers, the AC/DC converter controls real and reactive power received from the grid, while the DC/DC stage manages the current sent to the EV battery. Since our focus is the grid-integration and its implementation using HIL, only the AC/DC stage is analyzed. Fig. 1 shows the baseline AC/DC converter topology and its control-loop developed for this study. It uses a full-bridge active front-end rectifier and a resistor connected to the DC output. This configuration can easily emulate the behaviour of an on-board charger for advanced grid services and simultaneously realize battery charging without needing an actual battery pack model. This is especially advantageous for future hardware testing of EV-grid integration without the need to maintain a fail-proof battery testing environment. The system design specifications are listed in Table I. The parameters are selected to be compatible with a future actual hardware demonstration using wide band-gap SiC MOSFETs.

B. Modeling of the Converter Transfer Function

The modeling and controller design approach follows a similar methodology presented in [6], [18]. This design employs a bipolar modulation technique, where the switches operate in pairs. When switches S_1 and S_4 are on, switches S_2 and S_3 are off. This means that the voltage V_{in} is either $+V_{dc}$ or $-V_{dc}$, with no instance of $V_{in} = 0$. If we replace the full bridge in Fig.1 with a black box that has AC and DC terminals, we get the average (free of switching devices) representation of the converter as depicted in Fig.2. To derive the relationship between the input current and the control input, the relationship between the AC and DC terminals must be defined.




Figure 2: Average model of the AC/DC converter.

The relationship between the input and output currents and voltages can be found if the circuit is averaged over a switching period. The output capacitance (C_{dc}) is assumed to be high enough to keep the DC voltage (V_{dc}) constant. Assuming the full-bridge circuit is lossless, we can write:

$$\begin{aligned} v_{in} &= m \cdot V_{dc} \\ i_s &= \frac{I_o}{m} \end{aligned} \quad (1)$$

where

$$\begin{aligned} m &= M \cdot \sin(\omega_0 t - \delta), \quad |M| \leq 1, \\ v_s &= \sqrt{2} V_s \sin(\omega_0 t). \end{aligned} \quad (2)$$

m is the sinusoidal modulation index, M is the modulation index amplitude, I_o is the output DC current flowing into the RC network, i_s is the grid current, and ω_0 is the grid angular frequency. By applying KVL around the loop on the AC side of the circuit, the following differential equation is obtained:

$$\frac{di_s}{dt} = -\frac{R_L}{L_s} i_s + \frac{1}{L_s} v_s - \frac{1}{L_s} \underbrace{v_{in}}_{mV_{dc}}. \quad (3)$$

After taking the Laplace transform of both sides, the following expression is obtained:

$$\begin{aligned} sI_s(s) + \frac{R_L}{L_s} I_s(s) &= \frac{1}{L_s} V_s(s) - \frac{V_{dc}}{L_s} M(s) \\ I_s(s) \left(s + \frac{R_L}{L_s} \right) &= \frac{1}{L_s} V_s(s) - \frac{V_{dc}}{L_s} M(s) \\ I_s(s) &= \frac{1}{R_L + sL_s} V_s(s) - \frac{V_{dc}}{R_L + sL_s} M(s). \end{aligned} \quad (4)$$

Here, the transfer function between the input current i_s and the control input m is found to be

$$G_P(s) = \frac{I_s(s)}{M(s)} = -\frac{V_{dc}}{R_L + sL_s}. \quad (5)$$

We should note that v_s is a sinusoidal voltage, and it is fully coupled with the system. Therefore, we can model it as a sinusoidal disturbance to the system that is supposed to be eliminated by the controller.

III. CONTROLLER DESIGN

This design consists of two controller stages. The first stage is the inner-loop current controller, and the second stage is comprised of the outer-loop active power (P), reactive power (Q), and DC bus voltage (V_{dc}) controllers. The controller meets the P demand via dynamically adjusting the dc-link voltage between 340-800 V.

The current controller could be designed by considering the system's average model (5) transfer function, and the outer




Figure 3: Closed-loop block diagram of the system.

loop parameters can be tuned via empirical trial and error methods. The block diagram of the designed system is shown in Fig. 3. Plant refers to the converter transfer function and $G_c(s)$ is the current controller. The reference input (i_{ref}) to the system will be a sinusoidal signal. The disturbance (v_s) is also sinusoidal at the same frequency as the reference. Therefore, the controller ($G_c(s)$) must have a very large gain at ω_0 to reject all the disturbances and eliminate the steady-state errors.

One controller structure that is known to have a large gain at a specific frequency is the proportional resonant (PR) controller. The transfer function of a typical PR controller is shown below.

$$G_c(s) = K_p + \frac{2K_i\omega_c}{s^2 + 2\omega_c s + \omega_0^2}. \quad (6)$$

To tune the controller, first an arbitrary and reasonable pair of K_p and K_i are chosen. In this design, we set $K_p = 1$ and $K_i = 500$, and ω_c is chosen to be 2π rad/s. Although these coefficients result in a stable response with infinite gain margin and positive phase margin, the bandwidth (cross-over frequency) of the system is too high for the digital controller to respond (i.e., 1 Mrad/s). After inserting a gain of 0.1 in the controller path to slow down the response, the cross-over frequency of the new system with the PR controller is now 100 krad/s. The new (G_c) then becomes:

$$G_c(s) = \frac{-0.1s^2 - 629.6s - 1.421 \cdot 10^4}{s^2 + 12.57s + 1.421 \cdot 10^5}. \quad (7)$$

The resulting frequency response of the loop transfer function $G_L(s) = G_C(s) \times G_P(s)$ is shown in Fig. 4.

This continuous domain transfer function is converted to discrete-time using a sampling frequency of 72 kHz: (8).

$$G_c(z) = \frac{-0.1z^2 + 0.1913z - 0.09126}{z^2 - 2z + 0.9998}. \quad (8)$$

The outer loop that handles the active and reactive power tracking should be slower than the inner current controller.




Figure 4: Final loop transfer function frequency response




Figure 5: System controller diagram for inner and outer loops [6].

The P-Q theory is a commonly used method to implement power measurements in a discrete environment [19]. With this method, the voltage and current measurements (V_α and I_α) are first delayed a quarter of a grid cycle to obtain the quadrature components (V_β and I_β). The P and Q values are then computed using a non-linear combination of the delayed and present voltage and current components:

$$\begin{aligned} P &= 0.5 \times (V_\alpha I_\alpha + V_\beta I_\beta) \\ Q &= 0.5 \times (V_\alpha I_\beta - V_\beta I_\alpha) \end{aligned} \quad (9)$$

To eliminate the ripples on the power measurements, a discrete low pass filter (LPF) with a cut-off frequency of 20 Hz is used after the calculation of the quadrature components. For a given P and Q reference, the resulting input current is calculated as:

$$i_{ref} = \sqrt{2}I_s \sin(\omega_0 t + \theta) \quad (10)$$

where

$$\begin{aligned} I_s &= \frac{P_{ref}}{V_s \cos(\theta)} \\ \theta &= \tan^{-1}\left(\frac{Q_{ref}}{P_{ref}}\right) \end{aligned} \quad (11)$$

The outer loops are controlled by discrete PI controllers. The coefficients of the PI controllers for V-loop, P-loop and Q-loop shown in Fig. 5 are: $K_p^V=0.1$, $K_i^V=20$, $K_p^P=2.5$, $K_i^P=2.5$, $K_p^Q=0.1$, and $K_i^Q=20$.

IV. REAL-TIME HIL SIMULATION ANALYSIS

A. Dynamic Analysis of the Converter Operation

The controller was implemented in a TI TMS320F28335 DIMM100 based control card and tested using the Typhoon HIL 402 environment. We used an interface card to connect the DSP to Typhoon HIL 402. There are two test scenarios implemented to analyze the transient performance of the charger. Each test began with the converter operating at rated apparent power and unity power factor ($P_{ref}=10$ kW and $Q_{ref}=0$ kVAR). Then, a step response was provided at $t=0$ s to shift the desired converter output to two different power factors still at rated power, one is 0.707 pf lagging, and the other is 0.707 pf leading. Namely, Test#1 has $P_{ref}=10 \rightarrow 7.07$ kW and $Q_{ref}=0 \rightarrow 7.07$ kVAR; and Test#2




Figure 6: Transient test 1: grid voltage and current.




Figure 7: Transient test 2: grid voltage and current.

has $P_{ref}=10 \rightarrow 7.07$ kW and $Q_{ref}=0 \rightarrow -7.07$ kVAR. Resulting grid voltage and current can be seen in Figs. 6-7 for the two tests, showing successful transient performance.

B. Grid Integration Simulation

The on-board charger, implemented in Typhoon HIL 402, is integrated into a real-time grid simulator using OPAL-RT OP5600. The real-time grid simulation environment and its implementation are shown in Fig. 8. It features a 2.5 MVA, 230 kV/4.8 kV, 37-bus, three-phase balanced network for the distribution grid that is composed of residential house and EV loads. In total, this grid model has 10 neighborhoods with 16 homes in each neighborhood. The EV charger is operating in one of the 16 homes within a neighborhood. There are a total of 320 end-nodes. A diagram of the total HIL test system is shown in Fig. 8.

The grid simulator sends a grid voltage signal via the OPAL-RT to the converter and receives instantaneous current feedback from Typhoon HIL device to determine power con-




Figure 8: Overview of EV grid integration test system.




Figure 9: System hardware set-up.




Figure 10: System test results without AIMD.

sumption from that particular node. The actual hardware test system is constructed as seen in Fig. 9.

This system was tested with the grid simulation starting at approximately 5:30 PM when our load model starts to increase its power demand. The charger operates at a rated power of 10 kW. The system ran for about 50 min, and the results from this test are shown in Fig. 10. With the increasing load on the grid during the peak hours of the day, the particular end-node voltage has a decreasing trend. The charger does not respond to the increasing loading in the distribution grid and maintains drawing rated power.

In an attempt to mitigate this voltage drop and reduce the loading on the distribution grid, the additive increase-multiplicative decrease (AIMD) algorithm was implemented into the converter controller [20]. Per AIMD, when a decreasing trend in grid voltage is detected, the converter will automatically reduce its power consumption to compensate for the increased feeder congestion. The controller compares the grid voltage to a determined threshold value (V_{th}) every 10 seconds (algorithm period, T_a). This helps avoid very-fast dynamic disturbances of nearby loads that might cause throttling of the converter power if not filtered. If the grid voltage is below the threshold, the converter will multiplicatively decrease its power consumption by scaling it down by $\beta = 0.5$; and if the grid voltage is determined to be stable above the threshold, it will additively increase its power consumption by $\alpha = 100$ W. Eventually, the charger will converge to an average equilibrium charging power. The algorithm is shown in Alg. 1. This algorithm is implemented with a TI DSP.

The AC/DC converter uses past grid voltage measurements collected within the previous moving 1-min window (threshold update period, T_u) to dynamically update the threshold value by assigning it to the minimum recorded voltage in this window. A changing threshold allows the converter to adapt its charging power to the changing loading conditions in the grid.

Algorithm 1 Proposed AIMD

Parameter: Threshold update period: $T_u = 60s$
Parameter: Algorithm period: $T_a = 10s$
Input: Voltage meas. : $\vec{V}_i = [V_i(t - T_u) \cdots V_i(t)]$
Compute: $V_{th} = \min(\vec{V}_i)$ at every $t = T_u \times k, k \in \mathbb{N}$
Parameter: Additive increase parameter: $\alpha_i = 100W$
Parameter: Multiplicative decrease parameter: $\beta_i = 0.5$
Input: Previous P consumption: $P_i(t)$
Output: New P consumption: $P_i(t+1)$
Implement following at every $t = T_a \times k, k \in \mathbb{N}$:

- 1: **if** $V_i(t) > V_{th}$ **then**
- 2: $P_i(t+1) = P_i(t) + \alpha_i$
- 3: **else**
- 4: $P_i(t+1) = P_i(t) \times \beta_i$
- 5: **end if**




Figure 11: System test results with AIMD.

This is critical for a decentralized controller as node voltages vary based on location and other factors.

The full system was then retested with the AIMD algorithm implemented, and the results are shown in Fig. 11 in RMS form. In about 50 minutes of the constant power test, the grid voltage had fallen to approximately $226 V_{RMS}$ with a charging power of 10 kW. When the AIMD algorithm is used, the grid node voltage only dropped to a minimum of about $229 V_{RMS}$, but the charger was only able to operate at an average power of 3.9 kW. This 61% drop in charging power is significant, but was necessary to avoid congestion in the power distribution grid. The algorithm ran without a considerable extra taxation to the TI DSP closed-loop computation, proving its easy implementation at the charger end-node.

V. CONCLUSION

In this paper, the design, modeling, and implementation of a controller for a bidirectional AC/DC converter was studied. The HIL environment was used to accelerate the controller development and was tested without the risk of damaging actual hardware. The HIL-based converter was integrated into an external real-time grid simulator to study its impact on the operation of a complex grid model. The entire system was tested with the converter operating at constant rated power and the drop in node voltage was observed. The AIMD algorithm was then implemented in the converter controller as a compromise between node voltage drop and charging power.

In the future, we plan to construct a hardware version of this converter that will allow for high-power testing, accurate

loss measurements, and analysis of the accuracy of the HIL simulations. This converter will also be used in a real time high-power grid testbed, which will allow the full operation of the hardware to be validated and enable accurate experiments of algorithms to optimize grid stability.

REFERENCES

- [1] O. A. Alimi and K. Ouahada, "Smart home appliances scheduling to manage energy usage," pp. 1–5, 2018.
- [2] N. Fumo and M. Rafe Biswas, "Regression analysis for prediction of residential energy consumption," *Renewable and Sustainable Energy Reviews*, vol. 47, pp. 332–343, 2015. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S1364032115001884>
- [3] J. Sears, D. Roberts, and K. Glitman, "A comparison of electric vehicle level 1 and level 2 charging efficiency," pp. 255–258, 2014.
- [4] J. Voelcker, "Jd power study: Electric vehicle owners prefer dedicated home charging stations." <https://www.forbes.com/wheels/news/jd-power-study-electric-vehicle-owners-prefer-dedicated-home-charging-stations/>. [Online; accessed 21-Nov-2021].
- [5] M. C. Kisacikoglu, B. Ozpineci, and L. M. Tolbert, "EV/PHEV bidirectional charger assessment for V2G reactive power operation," *IEEE Trans. Power Electron.*, vol. 28, pp. 5717–5727, Dec. 2013.
- [6] M. C. Kisacikoglu, M. Kesler, and L. M. Tolbert, "Single-phase on-board bidirectional PEV charger for V2G reactive power operation," *IEEE Trans. Smart Grid*, vol. 6, no. 2, pp. 767–775, 2015.
- [7] S. Taghizadeh, M. Hossain, J. Lu, and W. Water, "A unified multi-functional on-board ev charger for power-quality control in household networks," *Applied Energy*, vol. 215, pp. 186–201, 04 2018.
- [8] E. Ucer, M. C. Kisacikoglu, and M. Yuksel, "Analysis of decentralized AIMD-based EV charging control," in *IEEE Power Energy Soc. General Meeting*, Aug 2019, pp. 1–5.
- [9] S. K. Bagudai, O. Ray, and S. Samantaray, "Evaluation of control strategies within hybrid dc/ac microgrids using typhoon hil," in *2019 8th International Conference on Power Systems (ICPS)*, 2019, pp. 1–6.
- [10] R. Chattopadhyay, A. De, and S. Bhattacharya, "Comparison of pr controller and damped pr controller for grid current control of lcl filter based grid-tied inverter under frequency variation and grid distortion," in *2014 IEEE Energy Conversion Congress and Exposition (ECCE)*, 2014, pp. 3634–3641.
- [11] E. Ucer, M. C. Kisacikoglu, and M. Yuksel, "Decentralized additive increase multiplicative decrease based electric vehicle charging," *IEEE Syst. J.*, vol. 15, no. 3, pp. 4272 – 4280, Aug. 2020.
- [12] M. Liu and S. McLoone, "Enhanced aimd-based decentralized residential charging of evs," *Transactions of the Institute of Measurement and Control*, vol. 37, no. 7, pp. 853–867, 2015. [Online]. Available: <https://doi.org/10.1177/0142331213494100>
- [13] A. Marinescu, A. Taylor, S. Clarke, I. Serban, and C. Marinescu, "Optimising residential electric vehicle charging under renewable energy: Multi-agent learning in software simulation and hardware-in-the-loop evaluation," *International Journal of Energy Research*, vol. 43, no. 8, pp. 3853–3868, 2019. [Online]. Available: <https://onlinelibrary.wiley.com/doi/abs/10.1002/er.4559>
- [14] V. Lakshminarayanan, G. Selvaraj, K. Rajashekara, L. Ben-Brahim, and A. Gastli, "Hardware in loop (hil) testing of energy management controller for electric vehicle integrated microgrid," in *2019 North American Power Symposium (NAPS)*, 2019, pp. 1–6.
- [15] I. Jayawardana, C. N. M. Ho, and Y. Zhang, "A comprehensive study and validation of a power-hil testbed for evaluating grid-connected ev chargers," *IEEE Journal of Emerging and Selected Topics in Power Electronics*, pp. 1–1, 2021.
- [16] Typhoon hil402. <https://www.typhoon-hil.com/products/hil402/>. [Online; accessed 21-Nov-2021].
- [17] Opal-RT Technologies. (2021) Versatile real-time digital simulator. [Online]. Available: <https://www.opal-rt.com/simulator-platform-op5600/>
- [18] M. Kisacikoglu, "Vehicle-to-grid (V2G) reactive power operation analysis of the EV/PHEV bidirectional battery charger," PhD Dissertation, University of Tennessee, 2013.
- [19] M. Haque, "Single-phase pq theory," in *2002 IEEE 33rd Annual IEEE Power Electronics Specialists Conference. Proceedings (Cat. No.02CH37289)*, vol. 4, 2002, pp. 1815–1819 vol.4.
- [20] E. Ucer, N. Erdogan, S. Rahman, and M. Kisacikoglu, "Real-time simulation of EV grid integration with internet-inspired charging control," in *3rd E-Mobility Power Syst. Integr. Symp.*, Aug 2019, pp. 1–5.